App F IX-4

Previous References

P.
1931 .
(nil)

File No. 246-31

Serial Nos. 13

Later References

RECEIVED

General and Revenue Secretariat.

Serial Nos

Part B for May '33

SUBJECT.

Report of breakdown of a two million unit motor at Belagola

BC
10/6/33

L 5134

General and Revenue Secretariat | File No 246 of 1931 | [App F III—2

Serial No	
13	Letter no C28-28 dated 10th May 1932 from the Director of Health in Mysore, brings to the notice of Govt of a break down in the two million gallon motor at Belagola The question of granting a loan to the Mysore City Municipality, for the improvement of the existing System of water supply in the city, is separately under consideration. The Director of Health states that he is taking necessary action so that such break downs may not occur at the time of the Dasara Holidays hereafter Submitted for perusal 16/5/32 (Chatterjee) 16/5 18/5 18/5

NOTE—Contn Sheet

WD 0216—GPB—15 000—22-8-32

Mr 246-31-13.

GOVERNMENT OF MYSORE

DEPARTMENT OF HEALTH

5734

4885

J V KARVE, MB, ChB, DPH,
Director of Health

W C SWEET, BSc, MD, CPH,
Rockefeller Foundation
Consultant in Health

elephone No 340
elegram HEALTH

C 28-29
Encl

"GRACE VILLE," PALACE ROAD,

Bangalore, (S India), dated 10th May 1933

CHIEF SECTARY, G.M. 13 MAY 1933

GEN & REV. SECT'T. 16 MAY 1933 L. S. G. BRANCH Bangalore

FROM

J V KARVE, ESQ, MB, ChB (EDIN), DPH (LOND),
Director of Health with the Government of His Highness the Maharaja of Mysore

To

R. RANGA RAO, ESQ., B.A., B.L.,
Chief Secretary to the Government of Mysore,
Bangalore.

SIR,

I have the honour to bring to the notice of Government that there was again a break down in the two million unit motor at Belgola. The trouble started on the 30th inst. Arrangements have been made to put new coils in the motor by the Electrical Department. It is expected this work will be completed by the 10th inst.

Such break downs naturally affect the City's supply which has, therefore, to be carefully husbanded by judicious distribution.

This is the third trouble we have had since January last. This clearly shows how absolutely necessary it is to have spare units. Orders have been placed for the three - million unit at Belgola and it is expected it will be received and installed by about the end of August 1933

I hope such break downs will not occur at the time of His Highness's Birthday Festivities. I am however working out some proposals to meet any emergency.

I have the honour to be,
Sir,
Your most obedient servant

J V Karve

Director of Health.